

RJM Corporation  
Ten Roberts Lane  
Ridgefield, CT 06877  
203 438-6198

September 25, 1991



Mr. Aaron Nissen  
Intermountain Power Services Corporation  
850 West Brush Wellman Road  
Delta, UT 84624

Ref: Airflow Balancing  
RJM Proposal No. 910614

Dear Mr. Nissen:

The above referenced proposal for air distribution balancing can be modified as follows:


1. Baseline Air Distribution Analysis - \$34,300.00
2. Burner Balancing - \$300.00/burner/test

The baseline air distribution analysis is a fixed-fee price and is a required prerequisite for any balancing work.

Please note that at the conclusion of a balancing program, another complete 48 burner test is required to assure that all burners meet the balancing criteria. This post balancing test will be conducted at the \$300.00/burner/test rate. Also, the above costs are exclusive of any sales, excise or other taxes which if applicable, your company has agreed to pay.

IPSC will be informed of the need for balancing and how many burners are out of specification at the conclusion of the baseline testing. IPSC can then make a determination at that time whether or not to continue with the balancing program.

Very truly yours,

  
Richard J. Monro  
President

RJM/sv  
Anipscab.ltr

RJM Corporation  
Ten Roberts Lane  
Ridgefield, CT 06877  
203 438-6198

6482

**FACSIMILE TRANSMITTAL COVER SHEET**DATE: 9/25/91 FAX NO.: \_\_\_\_\_

Please deliver the following pages to:

COMPANY: IPSC NAME: Aaron NissenREFERENCE: Proposal No. 910614THIS FAX IS FROM: Richard J. MenroNumber of pages 2 (including cover sheet) transmitting from Xerox Telecopier  
7032 (telephone 203 431-8255)

MESSAGE:

---

---

---

---

---

---

---

If you do not receive all the pages, please call back as soon as possible. 203-438-6198.

IP7\_003230

MEMORANDUM

INTERMOUNTAIN POWER SERVICE CORPORATION

TO: S. Gale Chapman  
FROM: Dennis K. Killian  
DATE: September 27, 1991  
SUBJECT: Burner Air Flow Balancing on Unit 2  
FILE: 01.12.02, IGS91-3

Please approve the attached purchase requisition for secondary air flow balancing thru the burners on Unit 2 during the Fall 1991 Outage. This Outage is scheduled to begin October 28, 1991. RJM Corporation will conduct the testing and provide diagnostics for shrouding the outer air registers and for back plate positioning on the inner air registers. **Total estimated cost for the burner air flow testing and balancing is \$70,400.**

IPSC is recommending the burner air flow balancing to aid in the resolution of concerns with the burner setup and their operation. It is part of the on-going program for burner improvements. Burner improvement related contracts include: the RJM Design Evaluation of B&W's Burner, RJM Flame Stabilizers Purchase as an attachment to Unit 2's burners, and Purchase of new B&W Redesigned Burners.

IPSC will be responsible for the installation of the shrouding required for balancing the outer air registers. RJM will provide technical support on the installation. IPSC will also be responsible for mechanical and technician support of the testing.

Please reference the attached purchase requisition, burner air flow balancing specification, plus RJM's Proposal #910614 dated June 17, 1991.

Please contact Jerry Hintze or Aaron Nissen if you have further questions concerning this matter.

AEN:  
Attachments

IP7\_003231

## BURNER AIR FLOW BALANCING SPECIFICATIONS:

### 1.0 SCOPE OF WORK

1.1 The Contractor shall provide testing and diagnostic services to balance secondary air flow to individual burners on a burner row basis. Both the inner (spin) and outer air zones shall be tested, balanced and retested to verify acceptance criteria.

Intermountain Generating Station, Unit 2, will be made available at the end of its Fall Outage for testing and balancing purposes. Unit 2's Outage begins October 28, 1991 and a block of five days are tentatively scheduled for testing and balancing activities (reference attached schedule).

1.2 The Contractor shall provide technical support and manpower for two test crews to conduct simultaneous air flow testing.

IPSC will provide technical support for the test crews of one person per crew.

Outage time is of the essence. To be able to conduct the testing, balancing and retesting, multiple crews and shifts will be utilized to obtain desired results. A window of five days is being provided during the Outage to complete all testing and balancing activities.

Work shifts maybe scheduled day or night and of ten to twelve hour duration to accommodate outage and testing activities. IPSC will pay premium time beyond an eight hour shift.

1.3 The Contractor shall provide a minimum of three sets (with one in standby) of test probes and analyzers for conducting the burner air flow balancing. Spare parts, probe and analyzer shall be obtainable within one working day (overnight freight service), upon the event of equipment failure.

1.4 IPSC will provide brackets or jigs for insertion in the coal nozzles to accommodate the test probe assemblies. A minimum of twelve jigs will be provided.

Maintenance support will be provided by IPSC to move the jigs during the air flow testing.

1.5 IPSC will be responsible for the installation of the shrouding required for balancing the the outer air registers. RJM will provide technical support on the installation.

Testing will be conducted, most likely during the night shift, which would allow modifications for balancing to occur during the following day shift.

1.6 An air flow test shall be conducted on one of the burner rows, in final balanced configuration, at minimum secondary air flow to verify balanced flow in a simulated out-of-service configuration.

## 2.0 PERFORMANCE SPECIFICATIONS

2.1 All eight rows of six Babcock and Wilcox (B&W) dual register low NOx burners shall be balanced to within  $\pm 5.0\%$  on a burner row basis and  $\pm 10\%$  on perimeter (circumferential) loading thru each burner.

2.2 Air flow testing will be conducted at normal secondary air flow through the windbox that is being tested.

## 3.0 CONDITIONS

3.1 The Contractor shall provide initial burner register positions for both the inner and outer vanes and inner register back plate position, prior to the beginning of the Outage. The burner registers will then be preset from the windbox at the beginning of the Outage, prior to testing.

The testing will be conducted with the burners in as close to final setup as possible to simulate actual operating conditions. This will include all register vane positioning, plus installation of the flame stabilizers.

3.2 Parameters outside the control of the contractor will be taken into account, if balancing criteria cannot be achieved. These parameters include: inadequate time to complete retesting and balancing (less than allocated time) and balancing restrictions outside the scope of the burners (such as a windbox configuration that cannot be balanced without installation of straightening vanes, vortex breakers, etc.).

Payment for testing completed shall be on a time and materials basis with mobilization costs.

3.3 IPSC will reserve the right to cancel additional testing and balancing due to time or other an foreseen event.

MEMORANDUM

INTERMOUNTAIN POWER SERVICE CORPORATION

TO: Doug Ingraham  
FROM: Dennis K. Killian  
DATE: September 30, 1991  
SUBJECT: Authorization to Purchase Burner Air Flow  
Balancing Services on Unit 2  
FILE: 01.12.02, 14.9010

Please proceed with the attached purchase requisition for secondary air flow balancing thru the burners on Unit 2 during the Fall 1991 Outage. This Outage is scheduled to begin October 28, 1991. RJM Corporation will conduct the testing and provide diagnostics for shrouding the outer air registers and for back plate positioning on the inner air registers. **Total estimated cost for the burner air flow balancing is \$70,400.**

This is a sole source contract due to the unique specialty test equipment and software required to test both the inner and outer air zones of the burner. We are not aware of any other combustion engineering firm, other than RJM Corporation of Ridgefield, CT, capable of performing this type of testing and diagnostics.

IPSC will be responsible for the installation of the shrouding required for balancing the outer air registers. RJM will provide technical support on the installation. We will also be responsible for mechanical and technician support of the testing.

Please reference the attached purchase requisition, burner air flow balancing specification, plus RJM's Proposal #910614 dated June 17, 1991.

Please contact Jerry Hintze or Aaron Nissen if you have further questions concerning this matter.

AEN:  
Attachments

[ ] REQUISITION FOR CAPITAL EQUIPMENT

[XX] PURCHASE AUTHORIZATION FOR EXPENSE ITEMS

Date	9/10/91
Req./PA No	61652
P.O. No	
Vendor	
Terms	
FOB	
Terms	
Ship Via	
Conf. To:	

Purpose of Materials, Supplies or Services: Burner  
air flow testing, diagnostics and balancing of the  
outer and inner air registers during Unit 2's Fall  
1991 Outage.

Suggested Vendor: RJM Corporation  
 Attn: Richard Monroe  
 Ten Roberts Lane  
 Ridgefield, CT 06877  
 (203) 438-6198  
 FAX (203) 431-8255

Account No. 00-6528-503

Qty	Unit	Description	Unit Cost	Extension
1		Burner Air Flow Analysis on IGS Unit 2 during		\$ 34,300
		the Fall 1991 Outage which begins 10/28/91.		
112	ea	Burner Air Flow Balancing & Retesting on an "as	\$300	\$ 33,600
		needed" basis to meet perf criteria & time requir		
		Reference attached Specifications and RJM		
		Proposal for contract details.		
		Same terms and conditions as the Burner Design		
		Evaluation Contract.		
		IPSC's contact and interface person with RJM shall		
		be Mr. Richard Monroe.		
1		Travel for meetings (expenses plus per diem)		\$2,500
		as requested by IPSC.		
		TOTAL ESTIMATED COST		\$70,400.

Remarks: Please contact Jerry Hintze or Aaron Nissen with any questions.

Delivery requested by [Date] 10/28/91 Originator Aaron Nissen


Dept. Mgr/Supt. Date \_\_\_\_\_ Station Manager Date \_\_\_\_\_ Operating Agent Date \_\_\_\_\_

IP7\_003235



6" slotted, shrouded  
bolted arrangement

1" platform  
standoffs



Start w/ 1" area reduction to start with





PROJECT NO. \_\_\_\_\_ VO NO. \_\_\_\_\_ PAGE \_\_\_\_\_ OF \_\_\_\_\_  
ORIGINATED BY \_\_\_\_\_ DATE \_\_\_\_\_ CHECKED BY \_\_\_\_\_ DATE \_\_\_\_\_  
DESCRIPTION \_\_\_\_\_

## TEST PLAN: AIR FLOW BALANCING

Test Nights: <sup>to 12</sup> 10<sup>hour</sup> shifts

2 test crews ( 2 RJM  
2 IJSC Garry/Dave

- inner air
- outer register
- (1 backup probe)

Mainit Crew Support to move test jigs  
(better than 3 or 4 sets made)

Test entire unit (all 48 burners) on 1 backshift

assume: <sup>well 6min - 20min</sup> 10min/burner x 6 burners 60 min per row  
plus 30min to move to next row  
x 8 rows

Test, Balance, Retest

RJM

Richard Monroe 9/4/91

~~recommend~~  
test vanes - full open  
outer reg influenced

1% error for  $10^\circ$  axial

10% error of inner air flow

segmented windbox

test days

→ Landing backshift

48 burners

2 crews

8-10 hrs continuous testing

IBC provide 1 tech support

→ Baseline

ductwork modifications, if necessary  
predicted by Model

★ Instant - How bad you are?

● FedEx - Drawing



PROJECT NO. \_\_\_\_\_ WO NO. \_\_\_\_\_ PAGE \_\_\_\_\_ OF \_\_\_\_\_  
ORIGINATED BY \_\_\_\_\_ DATE \_\_\_\_\_ CHECKED BY \_\_\_\_\_ DATE \_\_\_\_\_  
DESCRIPTION \_\_\_\_\_

Slope

Schedule

instr  
a manpower  
software  
diagnostics  
Binding IPSC

+/- 3% burner to burner

How  
Who  
What  
When  
Where  
\$  
#

jig

2 tech ?

Min - 2 testing setups

20 hr coverage  
4 ~~hrs~~ crews 10 hrs

Max duration

12 brackets/jigs

balance w/ stabilizers ?  
in place

# MEMORANDUM

TO: Mr. Aaron Nissen, Intermountain Power Service Corporation

FROM: Mr. Richard J. Monro, RJM Corporation

DATE: September 4, 1991

RE: Airflow Balancing

Based on our telephone conversation today, I thought the following comments might be helpful to you in your planning:

1. A baseline airflow balance test must be performed on all 48 burners. The baseline test will tell us airflow deviations between burners and between windboxes.
2. After the baseline test has been performed, burners within individual windboxes can be balanced on a windbox-by-windbox basis. Additional full 48 burner tests might be required, depending on individual windbox test results.
3. Airflow testing requires that the air doors and air vanes be set in the full-flow, axial-flow position. Adjustments for swirl control are made after airflow balances have been achieved.
4. Testing the inner air zone with the swirler installed introduces test error due to the rotational momentum of the air. Best test results will be achieved by testing the inner zone airflows without the swirler in place.
5. ADA insitu balancing addresses airflow problems symptomatically at the burner level. Ideally, these test techniques and balancing techniques are used for fine tuning the airflow balances. Gross airflow imbalances can be minimized, but a fluids model should then be performed and corrective actions installed during the next outage and final ADA airflow balancing achieved at that time.
6. Balancing using ADA insitu probe techniques are very effective in most applications. However, severe flow disturbances due to ductwork configurations usually require modeling to correct the airflows to the windboxes. A decision will have to be made upon completion of the baseline testing to determine if severe ductwork problems exist and the extent to which ADA balancing should be attempted, if at all.

Setup is  
needed to test  
w/ swirlers  
in-place

Mr. Aaron Nissen  
September 4, 1991  
Memo - Page 2

7. RJM Corporation can provide two sets of test equipment and two crews for the airflow balancing work. IPSC is requested to supply two technicians for each shift to assist in probe handling.

**Babcock & Wilcox**

1. B&W has not responded to my memo of August 27, 1991. Don Langley is on vacation. I have asked his secretary to expedite the information we requested. Very shortly we will be unable to proceed with our engineering analysis due to the lack of this information. Could you please apply pressure from your end.
2. We do not have materials descriptions for the 800H metal. Do you have any technical information on this supplied to IPSC from B&W?

RJM/sv  
F:\WPDOCS\IPSCAN.MEM

---

RESPONSE:

Air flow testing

2 probes

10'6" nettle 3 spiders

Installation IPX  
REM technical support

Jerry

RJM technical support fulltime?